



| Type   |              | Split Type |                 |
|--|--------------|------------|-----------------|
| Model  | Indoor unit  |            | FSKIF-360CE3    |
|  | Outdoor unit |            | FSOIF-360CE3-3F |
| Sound power level at standard rating cond. (IDU/ODU)                 |              | [dB(A)]    | 61/69           |
| Refrigerant type   |              |            | R32             |
| Global warming potential (GWP)                                       |              |            | 675             |
| SEER   |              |            | 6.1             |
| Energy efficiency class in cooling                                   |              |            | A++             |
| Annual electricity consumption in cooling                            |              | [KWh/a]    | 645             |
| Design load in cooling mode (Pdesign)                                |              | [KW]       | 10.5            |
| SCOP (average season)  |              |            | 4.0             |
| Energy efficiency class in heating (average season)                  |              |            | A+              |
| Annual electricity consumption in heating (average season)           |              | [KWh/a]    | 3150            |
| Design load in heating mode (Pdesign)                                |              | [KW]       | 9               |
| Declared capacity at reference design condition (average season)     |              | [KW]       | 7.849           |
| Back heating capacity at reference design condition (average season) |              | [KW]       | 1.151           |

\* Refrigerant leakage contributes to climate change. Refrigerant with lower global warming potential (GWP) would contribute less to global warming than a refrigerant with higher GWP, if leaked to the atmosphere. This appliance contains a refrigerant fluid with a GWP equal to [ 675 ]. This means that if 1 kg of this refrigerant fluid would be leaked to the atmosphere, the impact on global warming would be [ 675 ] times higher than 1 kg of CO<sub>2</sub>, over a period of 100 years. Never try to interfere with the refrigerant circuit yourself or disassemble the product yourself and always ask a professional.

\*\* The annual energy consumption kWh per year, based on standard test results. Actual energy consumption will depend on how the appliance is used and where it is located.

\*\*\* The standard rating conditions: cooling -outdoor 35°C DB/24°C WB -indoor 27°C DB/19°C WB  
 heating -outdoor 7°C DB/6°C WB -indoor 20°C DB/15°C WB